

**Testing Lead in Drinking Water for  
Public Rental Housing (PRH) Estates completed in and after 2005  
Weekly Report**

Week Ending	Total No. of Samples Taken	Metal Parameter	Lead Content in Drinking Water Samples (µg/L)		Hong Kong Drinking Water Standards <sup>(1)</sup> (µg/L)
			Minimum	Maximum	
7-Oct-2018	15	Lead	<1	1	10

Note:

- (1) The Government currently adopts the corresponding guideline values/provisional guideline values in the fourth edition of the World Health Organization's Guidelines for Drinking-water Quality ("WHO Guidelines") published in 2011 as the Hong Kong Drinking Water Standards.