

Housing Authority Surprise Safety Inspection Programme (SSIP)

Good & Bad Practices

香港房屋委員會
突擊安全巡查計劃

Q3 2013 良好及不良作業



職業安全健康局
OCCUPATIONAL SAFETY & HEALTH COUNCIL



 **WORKING AT HEIGHT**
高空工作

自動升降台於不使用時以帆布遮蓋
Mobile platform was covered when not in use



於吊船上清晰顯示安全資訊 Safety information displayed clearly at SWP



履帶式吊重機裝有供上落的梯子
Access ladder installed at crawler crane



終止環：附有索眼心環的絞接繩

Termination loop:

Spliced rope end with thimble



終止結：雙8字結(或稱翻穿8字結)

Termination knot:

Double figure-of-eight knot (or called figure-of-eight follow through with overhand backup)

繩尾留最少200毫米或
打上半結鎖緊8字結
A tail of at least 200
mm or tied with a
overhand knot





Figure Eight Follow-Through with Overhand backup.



有眼螺栓
eyebolt


穿索鐵鎖
karabiner

由合資格人士打結
Tied by competent person


Reference:

1. CAS. Extract of training notes. HK: Civil Aid Service.
2. HSE. (2001). *Industrial rope access – Investigation into items of personal protective equipment*. UK: Health & Safety Executive.
3. WSHC. (2012). *Workplace safety & health guidelines: Anchorage, lifelines and temporary edge protection systems*. SG: Workplace Safety & Health Council.

繩的保護裝置 Rope protector



由天然材料做，即帆布
或羊毛，平的或管型墊
Flat or tubular pads
made of natural fibers, ie
cotton(canvas) or wool



PVC保護器在鋒利的邊緣提供的保護很少，但仍聊勝於無。在一個圓形邊緣，PVC塗層脫落，在繩索上留下污漬的，增加摩擦及發熱。

PVC protectors provide little protection but are still better than nothing over a sharp edge. Over a rounded edge, PVC coating rubs off, leaving stains on the rope and increasing friction and hence heat.



HOUSEKEEPING

工作場所整理

大型圓筒形部件以楔子穩定並且被圍封
Large circular part was stabilized by stopper
and enclosed by barriers



分判商“架部”的通道暢通及有足夠照明
Corridor of sub-contractor site office was kept in good housekeeping condition and with sufficient lighting



清晰標示及區分洗手區及洗鞋區 Clear indication for washing areas



建築物料已妥善地圍封

Construction materials were properly fenced off



以保護蓋包裹鐵枝頭，並貼上黃黑色警告顏色
Covering of ends of iron bars



展示大型橫額以推廣工地整潔

Display large size banner to promote workplace tidiness and cleanliness



展示海報以推廣良好工地整理

Display poster to promote good housekeeping





LIFTING OPERATIONS

吊運作業

在吊運區加裝保護網防止工人被下墮物料撞傷
Protective net was installed in the lifting zone to protect against workers struck by falling object



天秤操作流動警號系統

Portable alarm system for tower crane operation





ELECTRICAL SUPPLY SYSTEM

供電系統

於電箱展示最新版本「電擊」法定海報 Display updated "Electric Shock" legal notice



以橫額提醒所有手提電工具必須是110V
Use banner to promote the use of 110V
handheld electric tools



Housing Authority Surprise Safety Inspection Programme (SSIP)

Good & Bad Practices

香港房屋委員會
突擊安全巡查計劃

QI 2014 良好及不良作業



職業安全健康局
OCCUPATIONAL SAFETY & HEALTH COUNCIL



 **WORKING AT HEIGHT**
高空工作

提供固定直梯予上落圍街板
Access ladder provided to the hoarding






HOUSEKEEPING

工作場所整理

清晰劃出物料存放區及吊運區範圍

Clear identification of storage and lifting area





LIFTING OPERATIONS

吊運作業

為電絞轆提供妥善保護 Proper protection of ECBs





ELECTRICAL SUPPLY SYSTEM

供電系統

貼出現時版本電擊處理海報

Display of current version of treatment for electric shock poster

